

ROSS VALLEY FIRE DEPARTMENT



Developed by

Robert Bastianon, Fire Inspector
Approved by

Roger Meagor, Fire Chief

Fire Protection Standard 205A

Illuminated Directory

Date: 8/8/08

Revision: _____

Page: 1 of 1

This standard has been developed for the purpose of clearly identifying and marking proper addresses pursuant to California Fire Code, Chapter 5, as adopted by ordinance by the Towns of Fairfax and San Anselmo.

- I. In addition to individual building suite or apartment numerals or letters, condominiums, apartment complexes, townhouses, mobile home parks and multiple commercial buildings shall have installed at points of entry, an illuminated directory sign.
- II. The directory sign shall consist of the following:
 - A. A plot plan showing private drives
 - B. Access Roads
 - C. Building locations with unit numbers and addresses.
 - D. Fire hydrant locations
 - E. Name of the complex
 - F. A reference point on the plot plan indicating the location of the directory
 - g. A north direction indicator
- III. The developer or the property owner shall submit to the Fire Department for review and approval a detailed plan showing size, materials, method of construction, electrical components and wiring, and location of installation.
- IV. Figure 1 indicates the minimum dimensions of the directory.

Note: Existing buildings constructed prior to the effective date of this standard need not conform to the illumination requirement of this standard.

Figure 1

